

Pembridge Residential Oil Tank Questionnaire

General Information

Policy # _____ Policy holder name _____

Location address (if different from mailing address) _____

Oil Tank Acceptability Guideline | Refer to your provincial property risk management guidelines

Photos: Yes No

Location of oil tank: Inside Outside Underground (unacceptable)

Label of certification: CSA ULC O-TL UL None

Age of tank (check sticker/stamp): _____

Tank Manufacturer: _____

Is sticker present? Yes No

Tank Type: 12 ga 14 ga Fiberglass Other Material
 Single Wall Double Wall Double Bottom

Is the tank inspected and serviced annually? Yes No If yes, by whom? _____

Tank Condition

Any rust, dents or corrosion evident? Yes No

Any signs of leaks, spills or overfilling? Yes No

Any dark spots? (Do not touch them) Yes No

Any fumes or odours evident? Yes No

Has the tank been painted? Yes No

Is the tank previously owned or re-conditioned? Yes No

Comments

Tank Support / Base Construction

Is the tank supported in a stable manner (fastened with a bracket)? Yes No

How is the tank supported? Dirt Concrete
 Wooden Other

Comments

Tank / Vent Location

Is oil tank accessible/visible for service/inspection? Yes No

Is the tank safe from vehicle impact? Yes No

Is the tank vented outside to the atmosphere? Yes No

Is the vent situated higher than the fill pipe? Yes No

Is the tank located at least 1.6 m / 5 ft from ignition source? Yes No

Is the tank near waterway lake or stream? Yes No

Comments

 If yes, provide distance: _____

Fuel Line

Is fuel line supply protected? Yes No

Is the fuel line protected where it passes through the foundation? Yes No

Is the fuel line looped? Yes No

Comments

Tank Protection

Is the tank sheltered? Yes No

Is the out-take valve protected? Yes No

Is the tank filled regularly? (keeping a tank filled prevents condensation buildup) Yes No

Comments

Comments

Brokerage Name _____

Broker Signature _____

Date _____